



Oil Heating Tank Questionnaire

Insured :	Policy Number :
Location :	Broker :
Date :	

All Oil Heating Tanks

Above ground and Outdoor Oil Heating Tanks

1. Tank age from label _____

2. Location of tank?
 Inside Outside Underground

3. Does the tank have a construction/approval label? If yes, by which association?
 CSA ULC

	Yes	No
4. Are the vent and filler pipes the same diameter?		
5. Are there any signs of leakage or spills?		
6. Any prior oil spillages?		
7. Are fumes or odours evident?		
8. Is the tank on a non-combustible, concrete/cement floor?		
9. Is there a loop in the fuel supply line?		
10. Is the tank located at least 1.5 meters (5 feet) from an ignition source?		
11. Is the tank inspected/serviced annually by a certified or licensed oil heating contractor?		

Remarks

	Yes	No
12. Is the tank protected from vehicle impact?		
13. Is the vent pipe higher than the filler pipe?		
14. Is the tank filled regularly, including the summer months?		
15. Has the tank been painted?		
16. Is the fuel supply line protected?		

Remarks

Please include a photo of the oil tank.